



8813 Hwy 41 South  
 Riverview, FL  
 Telephone: (813) 677-9111 - TELX52666  
 Fax: (813) 671-6283 ACCOUNTING

This product was produced at the  
 Production Plant - Riverview facility

**CAR NO: SHPX204520**

**Deliveries: 1001232016**

Material: Our / Your reference  
 200011 FLUOROSILICIC ACID /

#### Quality Certificate

Date  
 11/20/2012  
 Purchase order item/date  
 45399018 / 11/02/2012  
 Delivery item/date  
 1001232016 000010 / 11/19/2012  
 Order item/date  
 1482946 000010 / 11/02/2012  
 Customer number  
 5002715

Inspection lot 100000055094 from 11/19/2012

Characteristic	Result	Unit
Chemical Analysis		
Net H <sub>2</sub> SiF <sub>6</sub>	24.15	%
P <sub>2</sub> O <sub>5</sub>	0.12	%
Free Acid	0.35	%
Lead	0.00	ppm
Arsenic	52.50	ppm
Physical Analysis		
Density	1.2200	g/cm <sup>3</sup>
APHA	45	CU

\*We certify that product shipped with this  
 Certificate of Analysis meets AWWA B703-11\*



Kwasi Sakyi-Amfo  
 QC Lab Supervisor - Riverview



8813 Hwy 41 South  
 Riverview, FL  
 Telephone: (813) 677-9111 - TELX52666  
 Fax: (813) 671-6283 ACCOUNTING

This product was produced at the  
 Production Plant - Riverview facility

**CAR NO: GATX002036**

**Deliveries: 1001288234**

Material: Our / Your reference  
 200011 FLUROSILICIC ACID /

#### Quality Certificate

Date  
 01/29/2013  
 Purchase order item/date  
 45403267 / 01/09/2013  
 Delivery item/date  
 1001288234 000010 / 01/23/2013  
 Order item/date  
 1508377 000010 / 01/09/2013  
 Customer number  
 5002715

Inspection lot 100000056703 from 01/23/2013

Characteristic	Result	Unit
Chemical Analysis		
Net H <sub>2</sub> SiF <sub>6</sub>	23.53	%
P <sub>2</sub> O <sub>5</sub>	0.19	%
Free Acid	0.34	%
Lead	0.00	ppm
Arsenic	68.75	ppm
Physical Analysis		
Density	1.2130	g/cm <sup>3</sup>
APHA	70	CU

\*We certify that product shipped with this  
 Certificate of Analysis meets AWWA B703-11\*



Certified to  
 ANSINSE 60

Max. Use:  
 6 mg/L

Kwasi Sakyi-Amfo  
 QC Lab Supervisor - Riverview



8813 Hwy 41 South  
 Riverview, FL  
 Telephone: (813) 677-9111 - TELX52666  
 Fax: (813) 671-6283 ACCOUNTING

This product was produced at the  
 Production Plant - Riverview facility

**CAR NO: SHPX206904**

**Deliveries: 1001118379**

Material: Our / Your reference  
 200011 FLUOROSILICIC ACID /

#### Quality Certificate

Date  
 08/23/2012  
 Purchase order item/date  
 45392012 / 07/26/2012  
 Delivery item/date  
 1001118379 000010 / 08/13/2012  
 Order item/date  
 1434367 000010 / 07/26/2012  
 Customer number  
 5002715

Inspection lot 100000052663 from 08/13/2012

Characteristic	Result	Unit
Chemical Analysis		
Net H <sub>2</sub> SiF <sub>6</sub>	24.78	%
P <sub>2</sub> O <sub>5</sub>	0.11	%
Free Acid	0.35	%
Lead	0.00	ppm
Arsenic	45.75	ppm
Physical Analysis		
Density	1.2200	g/cm <sup>3</sup>
APHA	30	CU

\*We certify that product shipped with this  
 Certificate of Analysis meets AWWA B703-11\*



Kwasi Sakyi-Amfo  
 QC Lab Supervisor - Riverview